

NEGOTIATED PROCUREMENT (TWO FAILED BIDDINGS)

for

Preventive maintenance and services for Generator Sets for CY 2025

Sixth Edition July 2020

Table of Contents

Section	n I. Invitation to Bid for	4
Section	n II. Instructions to Bidders	6
1.	Scope of Bid	6
2.	Funding Information	6
3.	Bidding Requirements	6
4.	Corrupt, Fraudulent, Collusive, and Coercive Practices	6
5.	Eligible Bidders	6
6.	Origin of Goods	7
7.	Subcontracts	7
8.	Pre-Bid Conference	7
9.	Clarification and Amendment of Bidding Documents	7
10.	Documents comprising the Bid: Eligibility and Technical Components	8
11.	Documents comprising the Bid: Financial Component	8
12.	Bid Prices	8
13.	Bid and Payment Currencies	9
14.	Bid Security	9
15.	Sealing and Marking of Bids	9
16.	Deadline for Submission of Bids	10
17.	Opening and Preliminary Examination of Bids	10
18.	Domestic Preference	10
19.	Detailed Evaluation and Comparison of Bids	10
20.	Post-Qualification	11
21.	Signing of the Contract	11
	n III. Bid Data Sheet	
Section	n IV. General Conditions of Contract	13
1.	Scope of Contract	13
2.	Advance Payment and Terms of Payment	13
3.	Performance Security	13
4.	Inspection and Tests	13
5.	Warranty	14
6.	Liability of the Supplier	14
Section	n V. Special Conditions of Contract	15
Section	n VI. Schedule of Requirements	16
Section	n VII. Technical Specifications	17
Section	n VIII. Checklist of Technical and Financial Documents	20
SE	ECRETARY'S CERTIFICATE	27
SF	PECIAL POWER OF ATTORNEY	

NET FINANCIAL CONTRACTING CAPACITY	29
FINANCIAL BID FORM	
For Goods Offered from Within the Philippines	
Sealing and Marking of Bids:	



Section I. Invitation for Negotiated Procurement

Preventive maintenance and services for Generator Sets for CY 2025

In view of two (2) failed biddings, the UP Open University invites technically, legally, and financially capable suppliers to participate in the Negotiated Procurement for **Preventive maintenance and services for Generator Sets for CY 2025** in accordance with Section 53.1 (Two Failed Bidding) as specified in the Revised Implementing Rules and Regulations (IRR) of Republic Act (RA 9184), otherwise known as the "Government Procurement Reform Act".

The UP Open University, through the Government of the Philippines (GOP) General Appropriations Act of 2025 intends to apply the sum of **Six Hundred Sixty Thousand Pesos** (**PhP660,000.00**) being the Approved Budget for the Contract (ABC) to payments under the contract for the Early Procurement Activity (EPA) for the Procurement of "**Preventive maintenance and services for Generator Sets for CY 2025**" (NP-TFB No. 24-12-002). Bids received in excess of the approved budget for the contract (ABC) shall be automatically rejected at bid opening.

The UPOU now invites bids for the above Procurement Project. Bidders should have completed, within five (5) years from the date of submission and receipt of bids, a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II. Instructions to Bidders.

Bidding will be conducted through open competitive bidding procedures using a nondiscretionary "*pass/fail*" criterion as specified in the 2016 revised Implementing Rules and Regulations (IRR) of Republic Act (RA) No. 9184.

Bidding is restricted to Filipino citizens/sole proprietorships, partnerships, or organizations with at least sixty percent (60%) interest or outstanding capital stock belonging to citizens of the Philippines, and to citizens or organizations of a country the laws or regulations of which grant similar rights or privileges to Filipino citizens, pursuant to RA No. 5183.

Prospective Bidders may obtain further information from the BAC Secretariat and inspect the bidding documents at the address given below from 8:00 AM to 5:00 PM, Monday to Friday.

A complete set of Bidding Documents may be acquired by interested bidders from the address below and upon payment of the applicable fee pursuant to the latest Guidelines issued by the GPPB in the amount of **Seven Hundred Pesos (PhP 700.00)**. UPOU shall allow the bidder to present its proof of payment for the fees in person, by facsimile or through electronic means.

Bids must be duly received by the BAC Secretariat through manual submission at the office address indicated below <u>on or before 10 December 2024, 12:00 PM</u>.

All Bids must be accompanied by a bid security in any of the acceptable forms and in the amount stated in **ITB** Clause 14.

Bid opening shall be <u>on 10 December 2024, 2:30 PM</u> at the given address below and/or via video conferencing or any other means. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.

Late bids shall not be accepted.

The UPOU reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract at any time prior to contract award in accordance with Sections 35.6 and 41 of the 2016 revised IRR of RA No. 9184, without thereby incurring any liability to the affected bidder or bidders.

For further information, please refer to:

MS. ELVY A. PAMULAKLAKIN

Head, Bids and Awards Committee (BAC) Secretariat UPOU Headquarters, Los Baños, Laguna Telephone No.: (049) 536-6001-06 local 210-211 Telefax No.: (049) 536-5991 Email: <u>bac@upou.edu.ph</u>

You may visit the following websites:

For downloading of Bidding Documents: *https://www.upou.edu.ph/bids-and-awards-committee/*

28 November 2024

(SGD) **Dr. PRIMO G. GARCIA** Chair Bids and Awards Committee

Section II. Instructions to Bidders

1. Scope of Bid

The Procuring Entity, *UPOU* wishes to receive Bids for the **Preventive maintenance** and services for Generator Sets for CY 2025, with identification number NP-TFB No. 24-12-002.

The Procurement Project (referred to herein as "Project") is composed of *several items*, the details of which are described in Section VII (Technical Specifications).

2. Funding Information

- 2.1. The GOP through the source of funding as indicated below in the amount of PhP660,000.00.
- 2.2. The source of funding is General Appropriations Act of 2025.

3. Bidding Requirements

The Bidding for the Project shall be governed by all the provisions of RA No. 9184 and its 2016 revised IRR, including its Generic Procurement Manuals and associated policies, rules and regulations as the primary source thereof, while the herein clauses shall serve as the secondary source thereof.

Any amendments made to the IRR and other GPPB issuances shall be applicable only to the ongoing posting, advertisement, or **IB** by the BAC through the issuance of a supplemental or bid bulletin.

The Bidder, by the act of submitting its Bid, shall be deemed to have verified and accepted the general requirements of this Project, including other factors that may affect the cost, duration and execution or implementation of the contract, project, or work and examine all instructions, forms, terms, and project requirements in the Bidding Documents.

4. Corrupt, Fraudulent, Collusive, and Coercive Practices

The Procuring Entity, as well as the Bidders and Suppliers, shall observe the highest standard of ethics during the procurement and execution of the contract. They or through an agent shall not engage in corrupt, fraudulent, collusive, coercive, and obstructive practices defined under Annex "I" of the 2016 revised IRR of RA No. 9184 or other integrity violations in competing for the Project.

5. Eligible Bidders

- 5.1. Only Bids of Bidders found to be legally, technically, and financially capable will be evaluated.
- 5.2. Foreign ownership limited to those allowed under the rules may participate.

- 5.3. Pursuant to Section 23.4.1.3 of the 2016 revised IRR of RA No.9184, the Bidder shall have an SLCC that is at least one (1) contract similar to the Project the value of which, adjusted to current prices using the PSA's CPI, must be at least equivalent to:
 - a. For the procurement of Non-expendable Supplies and Services: The Bidder must have completed a single contract that is similar to this Project, equivalent to at least fifty percent (50%) of the ABC.
- 5.4. The Bidders shall comply with the eligibility criteria under Section 23.4.1 of the 2016 IRR of RA No. 9184.

6. Origin of Goods

There is no restriction on the origin of goods other than those prohibited by a decision of the UN Security Council taken under Chapter VII of the Charter of the UN, subject to Domestic Preference requirements under **ITB** Clause 18.

7. Subcontracts

7.1. The Bidder may subcontract portions of the Project to the extent allowed by the Procuring Entity as stated herein, but in no case more than twenty percent (20%) of the Project.

The Procuring Entity has prescribed that Subcontracting is not allowed.

7.2. Subcontracting of any portion of the Project does not relieve the Supplier of any liability or obligation under the Contract. The Supplier will be responsible for the acts, defaults and negligence of any subcontractors, its agents, servants, or workmen as fully as if there were the Supplier's own acts, defaults, or negligence, or those of its agents, servant, or workmen.

8. Pre-Bid Conference

The Procuring Entity will hold a pre-bid conference for this Project on the specified date and time and either at its physical address, **UPOU Headquarters, Los Banos, Laguna** and/or through videoconferencing/webcasting as indicated in paragraph 6 of the **IB**.

9. Clarification and Amendment of Bidding Documents

Prospective bidders may request for clarification on and/or interpretation of any part of the Bidding Documents. Such requests must be in writing and received by the Procuring Entity, either at its given address or through electronic mail indicated in the **IB**, at least ten (10) calendar days before the deadline set for the submission and receipt of Bids.

10. Documents comprising the Bid: Eligibility and Technical Components

- 10.1. The first envelope shall contain the eligibility and technical documents of the Bid as specified in Section VIII (Checklist of Technical and Financial Documents).
- 10.2. The Bidder's SLCC as indicated in **ITB** Clause 5.3 should have been completed within *5 years* prior to the deadline for the submission and receipt of bids.
- 10.3. If the eligibility requirements or statements, the bids, and all other documents for submission to the BAC are in foreign language other than English, it must be accompanied by a translation in English, which shall be authenticated by the appropriate Philippine foreign service establishment, post, or the equivalent office having jurisdiction over the foreign bidder's affairs in the Philippines. Similar to the required authentication above, for Contracting Parties to the Apostille Convention, only the translated documents shall be authenticated through an apostille pursuant to GPPB Resolution No. 13-2019 dated 23 May 2019. The English translation shall govern, for purposes of interpretation of the bid.

11. Documents comprising the Bid: Financial Component

- 11.1. The second bid envelope shall contain the financial documents for the Bid as specified in Section VIII (Checklist of Technical and Financial Documents).
- 11.2. If the Bidder claims preference as a Domestic Bidder or Domestic Entity, a certification issued by DTI shall be provided by the Bidder in accordance with Section 43.1.3 of the 2016 revised IRR of RA No. 9184.
- 11.3. Any bid exceeding the ABC indicated in paragraph 1 of the **IB** shall not be accepted.
- 11.4. For Foreign-funded Procurement, a ceiling may be applied to bid prices provided the conditions are met under Section 31.2 of the 2016 revised IRR of RA No. 9184.

12. Bid Prices

- 12.1. Prices indicated on the Price Schedule shall be entered separately in the following manner:
 - a. For Goods offered from within the Procuring Entity's country:
 - i. The price of the Goods quoted EXW (ex-works, ex-factory, exwarehouse, ex-showroom, or off-the-shelf, as applicable);
 - ii. The cost of all customs duties and sales and other taxes already paid or payable;

- iii. The cost of transportation, insurance, and other costs incidental to delivery of the Goods to their final destination; and
- iv. The price of other (incidental) services, if any, listed in e.
- b. For Goods offered from abroad:
 - i. Unless otherwise stated in the **BDS**, the price of the Goods shall be quoted delivered duty paid (DDP) with the place of destination in the Philippines as specified in the **BDS**. In quoting the price, the Bidder shall be free to use transportation through carriers registered in any eligible country. Similarly, the Bidder may obtain insurance services from any eligible source country.
 - ii. The price of other (incidental) services, if any, as listed in Section VII (Technical Specifications).

13. Bid and Payment Currencies

- 13.1. For Goods that the Bidder will supply from outside the Philippines, the bid prices may be quoted in the local currency or tradeable currency accepted by the BSP at the discretion of the Bidder. However, for purposes of bid evaluation, Bids denominated in foreign currencies, shall be converted to Philippine currency based on the exchange rate as published in the BSP reference rate bulletin on the day of the bid opening.
- 13.2. Payment of the contract price shall be made in Philippine Pesos.

14. Bid Security

- 14.1. The Bidder shall submit a Bid Securing Declaration or any form of Bid Security in the amount indicated in the **BDS**, which shall be not less than the percentage of the ABC in accordance with the schedule in the **BDS**.
- 14.2. The Bid and bid security shall be valid and shall not exceed one hundred twenty (120) calendar days from the date of the opening of bids. Any Bid not accompanied by an acceptable bid security shall be rejected by the Procuring Entity as non-responsive.

15. Sealing and Marking of Bids

Each Bidder shall submit one copy of the first and second components of its Bid.

The Procuring Entity may request additional hard copies and/or electronic copies of the Bid. However, failure of the Bidders to comply with the said request shall not be a ground for disqualification.

If the Procuring Entity allows the submission of bids through online submission or any other electronic means, the Bidder shall submit an electronic copy of its Bid, which must be digitally signed. An electronic copy that cannot be opened or is corrupted shall be considered non-responsive and, thus, automatically disqualified.

16. Deadline for Submission of Bids

16.1. The Bidders shall submit on the specified date and time and either at its physical address or through online submission as indicated in paragraph 7 of the **IB**.

17. Opening and Preliminary Examination of Bids

17.1. The BAC shall open the Bids in public at the time, on the date, and at the place specified in paragraph 9 of the **IB**. The Bidders' representatives who are present shall sign a register evidencing their attendance. In case videoconferencing, webcasting or other similar technologies will be used, attendance of participants shall likewise be recorded by the BAC Secretariat.

In case the Bids cannot be opened as scheduled due to justifiable reasons, the rescheduling requirements under Section 29 of the 2016 revised IRR of RA No. 9184 shall prevail.

17.2. The preliminary examination of bids shall be governed by Section 30 of the 2016 revised IRR of RA No. 9184.

18. Domestic Preference

18.1. The Procuring Entity will grant a margin of preference for the purpose of comparison of Bids in accordance with Section 43.1.2 of the 2016 revised IRR of RA No. 9184.

19. Detailed Evaluation and Comparison of Bids

- 19.1. The Procuring BAC shall immediately conduct a detailed evaluation of all Bids rated "*passed*," using non-discretionary pass/fail criteria. The BAC shall consider the conditions in the evaluation of Bids under Section 32.2 of the 2016 revised IRR of RA No. 9184.
- 19.2. If the Project allows partial bids, bidders may submit a proposal on any of the lots or items, and evaluation will be undertaken on a per lot or item basis, as the case maybe. In this case, the Bid Security as required by **ITB** Clause 15 shall be submitted for each lot or item separately.
- 19.3. The descriptions of the lots or items shall be indicated in Section VII (Technical Specifications), although the ABCs of these lots or items are indicated in the BDS for purposes of the NFCC computation pursuant to Section 23.4.2.6 of the 2016 revised IRR of RA No. 9184. The NFCC must be sufficient for the total of the ABCs for all the lots or items participated in by the prospective Bidder.
- 19.4. The Project shall be awarded as one contract.

19.5. Except for bidders submitting a committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation, all Bids must include the NFCC computation pursuant to Section 23.4.1.4 of the 2016 revised IRR of RA No. 9184, which must be sufficient for the total of the ABCs for all the lots or items participated in by the prospective Bidder. For bidders submitting the committed Line of Credit, it must be at least equal to ten percent (10%) of the ABCs for all the lots or items participated in by the prospective Bidder.

20. Post-Qualification

20.2. Within a non-extendible period of five (5) calendar days from receipt by the Bidder of the notice from the BAC that it submitted the Lowest Calculated Bid, the Bidder shall submit its latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS) and other appropriate licenses and permits required by law and stated in the **BDS**.

21. Signing of the Contract

21.1. The documents required in Section 37.2 of the 2016 revised IRR of RA No. 9184 shall form part of the Contract. Additional Contract documents are indicated in the **BDS**.

Section III. Bid Data Sheet

ITB	
Clause	
5.3	For this purpose, contracts similar to the Project shall be: a. Preventive maintenance of generator sets.
	b. completed within five (5) years prior to the deadline for the submission and receipt of bids.
7.1	No additional requirement.
12	The price of the Goods shall be quoted DDP at UP Open University Headquarters, or the applicable International Commercial Terms (INCOTERMS) for this Project.
14.1	 The bid security shall be in the form of a Bid Securing Declaration, or any of the following forms and amounts: a. The amount of not less than ₱13,200.00 [(2%) of ABC], if bid security is in cash, cashier's/manager's check, bank draft/guarantee or irrevocable letter of credit; or b. The amount of not less than ₱33,000.00 [(5%) of ABC] if bid security is in Surety Bond.
19.3	No additional requirement.
20.2	 (a) Latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS) (b) Current year's Mayor's Permit (c) UP System Questionnaire (d) Other appropriate valid licenses and permits required by law, if applicable
21.2	No additional requirement.

Section IV. General Conditions of Contract

1. Scope of Contract

This Contract shall include all such items, although not specifically mentioned, that can be reasonably inferred as being required for its completion as if such items were expressly mentioned herein. All the provisions of RA No. 9184 and its 2016 revised IRR, including the Generic Procurement Manual, and associated issuances, constitute the primary source for the terms and conditions of the Contract, and thus, applicable in contract implementation. Herein clauses shall serve as the secondary source for the terms and conditions of the Contract.

This is without prejudice to Sections 74.1 and 74.2 of the 2016 revised IRR of RA No. 9184 allowing the GPPB to amend the IRR, which shall be applied to all procurement activities, the advertisement, posting, or invitation of which were issued after the effectivity of the said amendment.

Additional requirements for the completion of this Contract shall be provided in the **Special Conditions of Contract (SCC).**

2. Advance Payment and Terms of Payment

- 2.1. Advance payment of the contract amount is provided under Annex "D" of the revised 2016 IRR of RA No. 9184.
- 2.2. The Procuring Entity is allowed to determine the terms of payment on the partial or staggered delivery of the Goods procured, provided such partial payment shall correspond to the value of the goods delivered and accepted in accordance with prevailing accounting and auditing rules and regulations. The terms of payment are indicated in the SCC.

3. Performance Security

Within ten (10) calendar days from receipt of the Notice of Award by the Bidder from the Procuring Entity but in no case later than prior to the signing of the Contract by both parties, the successful Bidder shall furnish the performance security in any of the forms prescribed in Section 39 of the 2016 revised IRR of RA No. 9184.

4. Inspection and Tests

The Procuring Entity or its representative shall have the right to inspect and/or to test the Goods to confirm their conformity to the Project specifications at no extra cost to the Procuring Entity in accordance with the Generic Procurement Manual. In addition to tests in the **SCC**, **Section IV (Technical Specifications)** shall specify what inspections and/or tests the Procuring Entity requires, and where they are to be conducted. The Procuring Entity shall notify the Supplier in writing, in a timely manner, of the identity of any representatives retained for these purposes. All reasonable facilities and assistance for the inspection and testing of Goods, including access to drawings and production data, shall be provided by the Supplier to the authorized inspectors at no charge to the Procuring Entity.

5. Warranty

- 6.1. In order to assure that manufacturing defects shall be corrected by the Supplier, a warranty shall be required from the Supplier as provided under Section 62.1 of the 2016 revised IRR of RA No. 9184.
- 6.2. The Procuring Entity shall promptly notify the Supplier in writing of any claims arising under this warranty. Upon receipt of such notice, the Supplier shall, repair or replace the defective Goods or parts thereof without cost to the Procuring Entity, pursuant to the Generic Procurement Manual.

6. Liability of the Supplier

The Supplier's liability under this Contract shall be as provided by the laws of the Republic of the Philippines.

If the Supplier is a joint venture, all partners to the joint venture shall be jointly and severally liable to the Procuring Entity.

Section V. Special Conditions of Contract

GCC Clause	
1	None.
2.2	The terms of payment shall be for every six months or semi-annual billing based on the actual number of units serviced for the period.
4	None.

Section VI. Schedule of Requirements

The delivery schedule expressed as days/weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item Number	Description	Quantity	Total	Delivery Period. days upon receipt of Notice to Proceed and Purchase Order
1	Preventive maintenance and services for Generator Sets for CY 2025	1 10	ot	12 months or 1 year

I hereby verify to comply with all the above requirements.

Signature over printed name of the authorized representative

Company name

Date

Section VII. Technical Specifications

Item	Specification	Statement of Compliance
	Notes: [Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution.]	
1	 GENSET MODEL 1) 150 KVA Lovol - Main Building 2) 112 KVA Lovol - Annex 3) 40KVA Yangzhou - CCDL 4) AKSA 125 - Community Hub 5) 125kVA FG Wilson -TLH 6) Onis – Administration Building 7) Perkins DGS JP438 - ICC Building 8) AR Genset (New and no brand yet) 9) ICC Genset (New and no brand yet) 10) World-Class Multimedia Production Bldg. Genset 	
	 SCOPE OF WORKS I. PREVENTIVE MAINTENANCE OF GENSETS A. COOLING SYSTEM a. Check radiator water level b. Check water leaks (if any) c. Check all radiator hoses B. CHECK FUEL SYSTEM a. Check fuel level b. Check fuel filters C. AIR INDUCTION & EXHAUST SYSTEM a. Check air cleaner b. Check exhaust pipe D. LUBE OIL SYSTEM a. Check oil level 	

b. Check oil leaks (if any) E. STARTING SYSTEM a. Check battery cluid and terminals c. Check battery cluid and terminals c. Check and belts d. Check alternator belts F. CONTROL PANEL a. Check all fuses c. Check all fuses c. Check all fuses c. Check all electrical connections d. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Coltage b. Frequency/rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage b. Frequency/RPM c. Current d. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exaiter stator windings b. Check main rotor d. Check main rotor d. Check main tertor battery c. Check main rotor d. Check armature windings c. Check and the connections at g. The main alternator box and circuit g. 2 breaker panel h. Simulate protective devices h. 1 Low oil pressure shutdown h. 2 High water temperature shutdown h. 3 Over speed shutdown (if any) h. 4 Over crash shutdown (if any) h. 4 Over states shutdown (if any) h. Check tarbor motor c. Check tarbor condition d. Check turbocharger (if fitted)		
 a. Check battery fluid and terminals b. Check battery fluid and terminals c. Check fan belts d. Check alternator belts F. CONTROL PANEL a. Check PBC and module b. Check all fuses c. Check all electrical connections d. Check meters and gauges G. SANITATION a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage b. Frequency/RPM c. Current d. Oil pressure c. Water temperature f. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure c. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check amin stator c. Check amin stator c. Check amin stator c. Check AVR and its connection g. Check aver temperature shutdown h. 2 breaker panel h. Simulate protective devices h. 1 Low oil pressure shutdown h. 3 Over speed shutdown (if any) h. 4 Over crank shutdown (if any) b. Check statter motor c. Check battery condition d. Check tattery condition d. Check tattery condition d. Check tattery condition d. Check		
 b. Check battery fluid and terminals c. Check fan belts d. Check alternator belts F. CONTROL PANEL a. Check PBC and module b. Check all fuses c. Check all fuses c. Check all fuses c. Check all electrical connections d. Check meters and gauges G. SANITATION a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/ rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check excitter stator windings b. Check amature windings c. Check main rotor d. Check AVR and its connections at g. Check AVR and its connections at g. The main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) b. Check statter motor c. Check battery condition d. Check tightness at the flywheel 		
 c. Check fan belts d. Check alternator belts F. CONTROL PANEL a. Check PBC and module b. Check all electrical connections d. Check meters and gauges G. SANITATION a. Check cleanliness H. TEST WITHUOT LOAD (at least 15 minutes) a. Voltage b. Frequency/rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVTH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check amature windings c. Check main notor d. Check main stator e. Check rectifier assembly f. Check AVR and its connections at g. 1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h. CONTROL PANEL 		
d. Check alternator belts F. CONTROL PANEL a. Check PBC and module b. Check all fuses c. Check all electrical connections d. Check meters and gauges G. SANITATION a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check rettifier assembly f. Check AVR and its connections at g. Check protective devices h. I temain alternator box and circuit g.2 breaker panel h. Simulate protective devices h. 1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel		
F. CONTROL PANEL a. Check PBC and module b. Check all fuses c. Check all electrical connections d. Check maters and gauges G. SANITATION a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check waiter stator windings b. Check main rotor d. Check main rotor d. Check main totor g. Check power cable connections at g. 1 the main alternator box and circuit g. 2 breaker panel h. Simulate protective devices h. 1 Low oil pressure shutdown h. 2 High water temperature shutdown h. 3 Over speed shutdown (if any) L. CONTROL PANEL A. Check stater motor c. Check tightness at the flywheel		
 a. Check PBC and module b. Check all fuscs c. Check all electrical connections d. Check meters and gauges G. SANITATION a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check main rotor d. Check main stator c. Check main stator c. Check rower cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h. Control PANEL a. Check stater motor c. Check pover conkinduoy (if any) h. Control PANEL a. Check stater motor c. Check stater mature shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) 		
 b. Check all fuses c. Check all electrical connections d. Check meters and gauges G. SANITATION a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/ rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check avaiter windings b. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check tightness at the flywheel 		
 c. Check all electrical connections d. Check meters and gauges G. SANITATION a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage b. Frequency/RPM c. Current d. Oil pressure c. Water temperature f. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure c. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check amature windings b. Check main stator c. Check main stator c. Check rower cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over condition d. Check battery condition d. Check tightness at the flywheel		
d. Check meters and gauges G. SANITATION a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/ rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage 1. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check main rotor d. Check main stator e. Check main stator e. Check armature windings c. Check AVR and its connection g. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.3 Over speed shutdown (if any) h. Over speed shutdown (if any) b. Check starter motor c. Check attert motor d. Check starter motor c. Check starter motor d. Check starter motor c. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check starter motor		
G. SANITATION a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/ rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check main stator c. Check main stator c. Check main stator c. Check main stator c. Check arnature windings c. Check main stator c. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.3 Over speed shutdown (if any) L. CONTROL PANEL a. Check tatter motor c. Check statter motor c. Check tatter motor		
 a. Check cleanliness H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) b. Check stater motor c. Check battery condition d. Check tightness at the flywheel 		
H. TEST WITHOUT LOAD (at least 15 minutes) a. Voltage b. Frequency/ rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage 1. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main rotor d. Check main stator c. Check reatifier assembly f. Check AVR and its connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h. 1 Low oil pressure shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel		
 a. Voltage b. Frequency/ rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check ania totor d. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) b. Check starter motor c. Check starter motor 		
 b. Frequency/ rpm c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connections at g. I the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check tightness at the flywheel 		
 c. Oil pressure d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) b. Check stater motor c. Check stater motor c. Check stater motor c. Control PANEL a. Check ightness at the flywheel 		
 d. Water temperature e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check main stator e. Check power cable connections at g. 1 the main alternator box and circuit g. 2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) b. Check starter motor c. Check tightness at the flywheel 		
 e. Running hour meter f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check main stator e. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) b. Check stater motor c. Check stater motor c. Check tightness at the flywheel 	-	
f. Battery voltage I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g. 1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h. 1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) b. Check statter motor c. Check tightness at the flywheel	=	
I. TEST WITH LOAD a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check amin rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) b. Check statter motor c. Check tightness at the flywheel		
 a. Voltage b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 		
 b. Frequency/RPM c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check tightness at the flywheel 	I. TEST WITH LOAD	
 c. Current d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 	6	
 d. Oil pressure e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check tightness at the flywheel 	1 1	
 e. Water temperature f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check tightness at the flywheel 		
f. Test AVR & exciter J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel	-	
J. MEGGER TEST a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) b. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel	-	
 a. Insulation K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) b. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 		
 K. POWER GENERATOR a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check tightness at the flywheel 	J. MEGGER TEST	
 a. Check exciter stator windings b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 		
 b. Check armature windings c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 		
 c. Check main rotor d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 	a. Check exciter stator windings	
 d. Check main stator e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) h.4 Over crank shutdown (if any) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 	6	
 e. Check rectifier assembly f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 		
 f. Check AVR and its connection g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 	d. Check main stator	
g. Check power cable connections at g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel	•	
g.1 the main alternator box and circuit g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel		
g.2 breaker panel h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel	g. Check power cable connections at	
 h. Simulate protective devices h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 	g.1 the main alternator box and circuit	
 h.1 Low oil pressure shutdown h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 	• •	
 h.2 High water temperature shutdown h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 	h. Simulate protective devices	
h.3 Over speed shutdown (if any) h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel		
h.4 Over crank shutdown (if any) L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel	e i	
L. CONTROL PANEL a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel	h.3 Over speed shutdown (if any)	
 a. Check governor/injection pump (adjust if necessary) b. Check starter motor c. Check battery condition d. Check tightness at the flywheel 	h.4 Over crank shutdown (if any)	
b. Check starter motorc. Check battery conditiond. Check tightness at the flywheel	L. CONTROL PANEL	
c. Check battery condition d. Check tightness at the flywheel	a. Check governor/injection pump (adjust if necessary)	
d. Check tightness at the flywheel	b. Check starter motor	
	c. Check battery condition	
e. Check turbocharger (if fitted)	d. Check tightness at the flywheel	
	 e. Check turbocharger (if fitted)	

 f. Check engine breather g. Check fuel lines (leaks of pipe) M. REPORT PREPARATION AND SUBMITTALS a. Report preparations. b. Submission of reports (progress report and test results) and warranty certificate. c. Conduct orientation on operations and maintenance of the installed units. 	
N. Restoration Restoration of walls, windows, ceiling and all finishes including painting and other related damages due to the preventive maintenance of genset.	
O. Quality Assurance Provision All works relative to the above project shall be assured of its quality/above par workmanship acceptable to UPOU. Any defects/flaws discovered shall be rectified the soonest possible time by the Contractor. Certification thereof shall be submitted duly signed and sealed by the manager or the authorized representative.	
P. This scope shall be done semi-annually.	
 Q. Personnel a. Mechanical Engineer (with valid license) - Min. 5 yrs. of experience b. Genset Technician - Min. 5 yrs. of experience c. Electrician (with NC II)/Registered Master Electrician (with valid license)/Registered Electrical Engineer (with valid license) - Min. 5 yrs. of experience 	

I hereby verify to comply with all the above requirements.

Signature over printed name of the authorized representative

Company name

Date:

I. TECHNICAL COMPONENT ENVELOPE

Class "A" Documents

Legal Documents

(a) Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages) in accordance with Section 8.5.2 of the IRR;

Technical Documents

- (b) Statement of the prospective bidder of all its ongoing government and private contracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid (UPOU BAC FORM No. 1); and
- (c) Statement of the bidder's Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided for in Sections 23.4.1.3 and 23.4.2.4 of the 2016 revised IRR of RA No. 9184, within the relevant period as provided in the Bidding Documents (UPOU BAC FORM No. 2). The SLCC should be at least 50% of the ABC;
- (d) Original copy of Bid Security. If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission;
 <u>Or</u>
 Original copy of Notarized Bid Securing Declaration (UPOU BAC FORM)

Original copy of Notarized Bid Securing Declaration (UPOU BAC FORM No. 3); and

- (e) Conformity with the Technical Specifications, Bidders must state under Statement of Compliance either "Comply" or "Not Comply" against each of the individual parameters of each specification (UPOU BAC FORM No. 4), which should include the following:
 - 1) Bio-Data for the following:
 - 1.1) Mechanical Engineer (with valid license) Min. 5 yrs. of experience
 - 1.2) Genset Technician Min. 5 yrs. of experience
 - 1.3) Electrician (with NC II)/Registered Master Electrician (with valid license)/Registered Electrical Engineer (with valid license)
 Min. 5 yrs. of experience

Notes: Personnel with multiple expertise and qualifications with at most two different positions mentioned above are allowed as long as he/she can provide the necessary documentation in support of his/her qualifications such as appropriate valid licenses, certificate of training, accreditation, and the like should be submitted separately for each position.

(f) Original duly signed Omnibus Sworn Statement (OSS) (UPOU BAC FORM No. 5);

and if applicable, Original Notarized Secretary's Certificate (UPOU BAC FORM No. 6) in case of a corporation, partnership, or cooperative; **or** Original Special Power of Attorney (UPOU BAC FORM No. 7) of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder; and

Financial Documents

(g) The prospective bidder's computation of Net Financial Contracting Capacity (NFCC) (UPOU BAC FORM No. 8);

<u>or</u>

A committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation.

Class "B" Documents

(h) If applicable, a duly signed joint venture agreement (JVA) in case the joint venture is already in existence. (UPOU BAC FORM No. 9)

<u>or</u>

duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful.

II. FINANCIAL COMPONENT ENVELOPE

- (a) Original of duly signed and accomplished Financial Bid Form (UPOU BAC FORM No. 10) which should include Secretary's Certificate or Special Power of Attorney, if applicable; and
- (b) Original of duly signed and accomplished Price Schedule(s) (UPOU BAC FORM No. 11b);.

Note:

The prescribed documents in the checklist are mandatory to be submitted in the Bid.

STATEMENT OF ALL ONGOING GOVERNMENT AND PRIVATE CONTRACTS INCLUDING CONTRACTS AWARDED BUT NOT YET STARTED

Business Name	·
Business Address	:

Name of Contract	Date of Contract	Contract Duration	Owner's Name and Address	Kinds of Goods	Amount of Contract	Value of Outstanding Contracts	Date of Delivery
Government							
<u>Private</u>							

Note: This statement shall be supported with any of the following:

1. End user's acceptance or official receipt(s) issued for the contract, if completed; or

2. Notice of Award and/or Contract

Submitted by :

(Printed Name & Signature)

Designation : Date :

UPOU BAC Form No. 2

STATEMENT OF BIDDER'S SINGLE LARGEST COMPLETED CONTRACT (SLCC) SIMILAR TO THE CONTRACT TO BE BID

Business Name : ______Business Address : _____

Name of Contract	Date of Contract	Contract Duration	Owner's Name and Address	Kinds of Goods	Amount of Completed Contract	Date of Delivery
Government						
Private						

Note: This statement shall be supported with any of the following:

1. End user's acceptance or official receipt(s) issued for the contract, if completed; or

2. Notice of Award and/or Contract

Submitted by

(Printed Name & Signature)

Designation : ______ Date : ______ REPUBLIC OF THE PHILIPPINES) CITY OF ______) S.S.

BID SECURING DECLARATION Project Identification: *NP-TFB No. 24-12-002*

To: [Insert name and address of the Procuring Entity]

I/We, the undersigned, declare that:

- 1. I/We understand that, according to your conditions, bids must be supported by a Bid Security, which may be in the form of a Bid Securing Declaration.
- 2. I/We accept that: (a) I/we will be automatically disqualified from bidding for any procurement contract with any procuring entity for a period of two (2) years upon receipt of your Blacklisting Order; and, (b) I/we will pay the applicable fine provided under Section 6 of the Guidelines on the Use of Bid Securing Declaration, within fifteen (15) days from receipt of the written demand by the procuring entity for the commission of acts resulting to the enforcement of the bid securing declaration under Sections 23.1(b), 34.2, 40.1 and 69.1, except 69.1(f),of the IRR of RA No. 9184; without prejudice to other legal action the government may undertake.
- 3. I/We understand that this Bid Securing Declaration shall cease to be valid on the following circumstances:
- a. Upon expiration of the bid validity period, or any extension thereof pursuant to your request;
- b. I am/we are declared ineligible or post-disqualified upon receipt of your notice to such effect, and (i) I/we failed to timely file a request for reconsideration or (ii) I/we filed a waiver to avail of said right; and
- c. I am/we are declared the bidder with the Lowest Calculated Responsive Bid, and I/we have furnished the performance security and signed the Contract.

IN WITNESS WHEREOF, I/We have hereunto set my/our hand/s this _____ day of [month] [year] at [place of execution].

[Insert NAME OF BIDDER OR ITS AUTHORIZED REPRESENTATIVE] [Insert signatory's legal capacity] Affiant

[Jurat]

[Format shall be based on the latest Rules on Notarial Practice]

REPUBLIC OF THE PHILIPPINES) CITY/MUNICIPALITY OF _____) S.S.

AFFIDAVIT

I, [Name of Affiant], of legal age, [Civil Status], [Nationality], and residing at [Address of Affiant], after having been duly sworn in accordance with law, do hereby depose and state that:

1. [Select one, delete the other:]

[If a sole proprietorship:] I am the sole proprietor or authorized representative of [Name of Bidder] with office address at [address of Bidder];

[If a partnership, corporation, cooperative, or joint venture:] I am the duly authorized and designated representative of [Name of Bidder] with office address at [address of Bidder];

2. [Select one, delete the other:]

[If a sole proprietorship:] As the owner and sole proprietor, or authorized representative of [Name of Bidder], I have full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity], as shown in the attached duly notarized Special Power of Attorney;

[If a partnership, corporation, cooperative, or joint venture:] I am granted full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity], as shown in the attached [state title of attached document showing proof of authorization (e.g., duly notarized Secretary's Certificate, Board/Partnership Resolution, or Special Power of Attorney, whichever is applicable;)];

- 3. [Name of Bidder] is not "blacklisted" or barred from bidding by the Government of the Philippines or any of its agencies, offices, corporations, or Local Government Units, foreign government/foreign or international financing institution whose blacklisting rules have been recognized by the Government Procurement Policy Board, by itself or by relation, membership, association, affiliation, or controlling interest with another blacklisted person or entity as defined and provided for in the Uniform Guidelines on Blacklisting;
- 4. Each of the documents submitted in satisfaction of the bidding requirements is an authentic copy of the original, complete, and all statements and information provided therein are true and correct;
- 5. [Name of Bidder] is authorizing the Head of the Procuring Entity or its duly authorized representative(s) to verify all the documents submitted;

6. [Select one, delete the rest:]

[If a sole proprietorship:] The owner or sole proprietor is not related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree; [If a partnership or cooperative:] None of the officers and members of [Name of Bidder] is related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

[If a corporation or joint venture:] None of the officers, directors, and controlling stockholders of *[Name of Bidder]* is related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

- 7. [Name of Bidder] complies with existing labor laws and standards; and
- 8. *[Name of Bidder]* is aware of and has undertaken the responsibilities as a Bidder in compliance with the Philippine Bidding Documents, which includes:
 - a. Carefully examining all of the Bidding Documents;
 - b. Acknowledging all conditions, local or otherwise, affecting the implementation of the Contract;
 - c. Making an estimate of the facilities available and needed for the contract to be bid, if any; and
 - d. Inquiring or securing Supplemental/Bid Bulletin(s) issued for the [Name of the Project].
- 9. *[Name of Bidder]* did not give or pay directly or indirectly, any commission, amount, fee, or any form of consideration, pecuniary or otherwise, to any person or official, personnel or representative of the government in relation to any procurement project or activity.
- 10. In case advance payment was made or given, failure to perform or deliver any of the obligations and undertakings in the contract shall be sufficient grounds to constitute criminal liability for Swindling (Estafa) or the commission of fraud with unfaithfulness or abuse of confidence through misappropriating or converting any payment received by a person or entity under an obligation involving the duty to deliver certain goods or services, to the prejudice of the public and the government of the Philippines pursuant to Article 315 of Act No. 3815 s. 1930, as amended, or the Revised Penal Code.
- IN WITNESS WHEREOF, I have hereunto set my hand this _____ day of ____, 20___ at ____, Philippines.

[Insert NAME OF BIDDER OR ITS AUTHORIZED REPRESENTATIVE] [Insert signatory's legal capacity] Affiant

[Jurat] [Format shall be based on the latest Rules on Notarial Practice]

SECRETARY'S CERTIFICATE

I,	, a duly elected and qualified Corporate Secretary of
	, a corporation duly organized and existing under and by virtue of the law of
the	, DO HEREBY CERTIFY, that:

I am familiar with the facts herein certified and duly authorized to certify the same;

At the regular meeting of the Board of Directors of the said Corporation duly convened and held on _______ at which meeting a quorum was present and acting throughout, the following resolutions were approved, and the same have not been annulled, revoked and amended in any way whatever and are in full force and effect on the date hereof:

RESOLVED, that _________be, as it hereby is, authorized to participate in the bidding for "Preventive maintenance and services for Generator Sets for CY 2025", Project Identification NP-TFB No. 24-12-002 by the <u>UP Open University</u> and that if awarded the project shall enter into a contract with the <u>UP Open University</u>: and in connection therewith hereby appoint _______, acting as duly authorized and designated representatives of _______, are granted full power and authority to do, execute and perform any and all acts necessary and/or to represent _______ in the bidding as fully and effectively as the _______ might do if personally present with full power of substitution and revocation and hereby satisfying and confirming all that my said representative shall lawfully do or cause to be done by virtue hereof;

RESOLVED FURTHER THAT, the ______ hereby authorizes its President to: (1) execute a waiver of jurisdiction whereby the ______ hereby submits itself to the jurisdiction of the Philippine government and hereby waives its right to question the jurisdiction of the Philippine courts;

WITNESS the signature of the undersigned as such officer of the said ______ this

(Corporate Secretary)

ACKNOWLEDGMENT

 SUBSCRIBED AND SWORN to before me this _____ day of _____, 20___ affiant exhibited

 to me his/her Government Issued ID No. ______ issued on ______ at

 _______, Philippines.

Notary Public
Until 31 December 20
PTR No.
Issued at:
Issued on:
TIN No

·

SPECIAL POWER OF ATTORNEY

Ι,	, President	of, a with its registered by virtue of Board Resolution No.
corporation incorporated under t	he laws of	with its registered
office at	,	by virtue of Board Resolution No.
dated	, has made, cor	nstituted and appointed
acts necessary and/or represent		in the bidding of
personally present with full power representative shall lawfully do c		n and hereby confirming all that said preof.
IN WITNESS WHEREO	DF, I have hereunto set may han at	
Signed in the Presence of:		Affiant
	ACKNOWLEDGMENT	Γ
REPUBLIC OF THE PHILIPPIN	NES)	
QUEZON CITY		
BEFORE ME, a Notary , 20, p		City, Philippines, this day of
NAME	Government Issued ID NO	<u>ISSUED AT/ON</u>

known to me and known to be the same person who executed the foregoing instrument consisting of ______ () pages, including the page whereon the acknowledgments is written and acknowledged before me that the same is his free and voluntary act and deed and that of the Corporation he represents.

WITNESS MY HAND AND NOTARIAL SEAL, at the place and on the date first above written.

Notary Public
Until 31 December 20
PTR No
Issued at:
Issued on:
TIN No.

Doc. No.	
Page No.	
Book No.	
Series of	

NET FINANCIAL CONTRACTING CAPACITY

The computation of a prospective bidder's Net Financial Contracting Capacity (NFCC) must be at least equal to the ABC to be bid (PhP660,000.00), calculated as follows:

ABC: PhP660,000.00	Year 20
Current Assets	
Minus: Current Liabilities	
Sub Total	
Multiplied by value of K	
Sub Total	
Minus: Value of outstanding services under ongoing contracts including awarded contracts yet to be started coinciding with the contract to be bid	
NFCC	

NFCC = [(current asset minus current liabilities) (15)] minus value of all outstanding or uncompleted portions of the projects under ongoing contracts including awarded contracts yet to be started coinciding with the contract to be bid.

NFCC = PhP_____

The values of the domestic bidder's current assets and current liabilities shall be based on the latest Audited Financial Statements submitted to the BIR.

Submitted by:

Name of Supplier / Distributor / Manufacturer

Signature of Authorized Representative Date : _____

NOTE:

^{1.} If Partnership or Joint Venture, each Partner or Member Firm of Joint Venture shall submit the above requirements.

JOINT VENTURE AGREEMENT

KNOW ALL MEN BY THESE PRESENTS:

That this JOI	NT VENTURE AGREEMENT	is entered into by and between , of
legal age,	owner/proprietor of	
	(civil status)	
and a resident of		
	- and	-
	, of legal age,	, owner/proprietor of
		(civil status)
	a resident of	·

THAT both parties agree to join together their manpower, equipment, and what is need to facilitate the Joint Venture to participate in the Eligibility, Bidding and Undertaking of the here-under stated project to be conducted by the UP Open University.

NAME OF PROJECT

CONTRACT AMOUNT

That both parties agree to be jointly and severally liable for the entire assignment.

That both parties agree that ______ and/or ______ shall be the Official Representative of the Joint Venture, and is granted full power and authority to do, execute and perform any and all acts necessary and/or to represent the Joint Venture in the bidding as fully and effectively and the Joint Venture may do and if personally present with full power of substitution and revocation.

THAT this Joint Venture Agreement shall remain in effect only for the above stated Project until terminated by both parties.

Done this _____ day of _____, in the year of our Lord _____.

ACKNOWLEDGMENT

 SUBSCRIBED AND SWORN to before me this _____ day of ______, 20___ affiant exhibited

 to me his/her Government Issued ID No. ______ issued on ______ at

 _______, Philippines.

Notary Public
Until 31 December 20
PTR No.
Issued at:
Issued on:
TIN No.

Doc. No.	
Page No.	
Book No.	
Series of	

FINANCIAL BID FORM

Date : _____ Project Identification No. : _____

To: [name and address of Procuring Entity]

Having examined the Philippine Bidding Documents (PBDs) including the Supplemental or Bid Bulletin Numbers *[insert numbers]*, the receipt of which is hereby duly acknowledged, we, the undersigned, offer the *Preventive maintenance and services for Generator Sets for CY 2025* in conformity with the said PBDs for the sum of *[total Bid amount in words and figures]* or the total calculated bid price, as evaluated and corrected for computational errors, and other bid modifications in accordance with the Price Schedules attached herewith and made part of this Bid. The total bid price includes the cost of all taxes, such as, but not limited to: *[specify the applicable taxes, e.g. (i) value added tax (VAT), (ii) income tax, (iii) local taxes, and (iv) other fiscal levies and duties]*, which are itemized herein or in the Price Schedules,

If our Bid is accepted, we undertake:

a. to deliver the goods in accordance with the delivery schedule specified in the Schedule of Requirements of the Philippine Bidding Documents (PBDs);

b. to provide a performance security in the form, amounts, and within the times prescribed in the PBDs;

c. to abide by the Bid Validity Period specified in the PBDs and it shall remain binding upon us at any time before the expiration of that period.

[Insert this paragraph if Foreign-Assisted Project with the Development Partner: Commissions or gratuities, if any, paid or to be paid by us to agents relating to this Bid, and to contract execution if we are awarded the contract, are listed below:

Name and address Amount and Purpose of of agent Currency Commission or gratuity

(if none, state "None")]

Until a formal Contract is prepared and executed, this Bid, together with your written acceptance thereof and your Notice of Award, shall be binding upon us.

We understand that you are not bound to accept the Lowest Calculated Bid or any Bid you may receive.

We certify/confirm that we comply with the eligibility requirements pursuant to the PBDs.

The undersigned is authorized to submit the bid on behalf of [name of the bidder] as evidenced by the attached [Secretary's Certificate or Special Power of Attorney, if applicable].

We acknowledge that failure to sign each and every page of this Bid Form, including the attached Schedule of Prices, shall be a ground for the rejection of our bid.

Name: _____

Legal capacity:

Signature:

Duly authorized to sign the Bid for and behalf of:

Date: _____

UPOU BAC Form No. 11b Revised 09/2020

Price Schedule

For Goods Offered from Within the Philippines

 Name of Bidder
 Project ID No.
 Page of

1	2	3	4	5	6	7	8	9	10
Item	Description	Country of origin	Quantity	Unit price EXW per item	Transporta tion and all other costs incidental to delivery,	Sales and other taxes payable if Contract is awarded, per	Cost of Incidental Services, if applicable, per item	Total Price, per unit (col 5+6+7+8)	Total Price delivered Final Destination (col 9) x
					per item	item			(col 4)
1	Preventive		1 lot						
	maintenance and								
	services for								
	Generator Sets for								
	CY 2025								

Name: _____

Legal Capacity:

Signature:

Duly authorized to sign the Bid for and behalf of:

BIO-DATA OF KEY PERSONNEL

Give the detailed information of the following personnel who are scheduled to be assigned as full-time J

field staff for the project. Fill out a form for each	ch person.	
- Authorized Managing Officer / Representative		
- Sustained Technical Employee		
1. Name:		
2. Date of Birth:		
3. Nationality:		
4. Education and Degrees:		
5. Specialty:		
6. Registration:		
7. Length of Service with the Firm: Year	from(months)	(year)
	to(months)	(year)
8. Years of Experience:		
9. If Item 7 is less than five (5) years, give name five (5)-year period (attached additional sheet Name and Address of Employer		
	year(s) from	to
	year(s) from year(s) from	to to
10. Experience:		
This should cover the past five (5) years of e show involvement of personnel in projects us		
1. Name:		
2. Name and Address of Owner:		
3. Name and Address of the Owner's Engine	er:	
4. Indicate the Features of Project (particular interest connected with the project):	s of the project compo	nents and any other particular
5. Contract Amount Expressed in Philippine	Currency:	
6. Position:		

7. Structures for which the employee was responsible:

8. Assignment Period: from _____ (months) _____ (years) : to _____ (months) _____ (years)

Name and Signature of Employee/Key Personnel

It is hereby certified that the above personnel can be assigned to this project, if the contract is awarded to our company.

(Place and Date)

(Bidder's Authorized Representative)

Sealing and Marking of Bids:

Submission of hard copies to the BAC Secretariat Address:

One Original Copy of the Technical Components and Financial Components

PROCEDURE:

1. The Technical Components (TC) of the Bid should be enclosed in envelope and must be labelled, sealed and signed as follows:

PREVENTIVE MAINTENANCE AND SERVICES FOR GENERATOR SETS FOR CY 2025 – TECHNICAL COMPONENTS

[NAME AND ADDRESS OF THE BIDDERS] BIDS AND AWARDS COMMITTEE SECRETARIAT UP OPEN UNIVERSITY UPOU HEADQUARTERS, LOS BAÑOS, LAGUNA REFERENCE NO. NP-TFB No. 24-12-002 "DO NOT OPEN BEFORE 10 December 2024, 2:30 PM"

2. The Financial Components (FC) of the Bid should be enclosed in another envelope and must be sealed and signed;

PREVENTIVE MAINTENANCE AND SERVICES FOR GENERATOR SETS FOR CY 2025 – FINANCIAL COMPONENTS

[NAME AND ADDRESS OF THE BIDDERS] BIDS AND AWARDS COMMITTEE SECRETARIAT UP OPEN UNIVERSITY UPOU HEADQUARTERS, LOS BAÑOS, LAGUNA REFERENCE NO. NP-TFB No. 24-12-002 "DO NOT OPEN BEFORE 10 December 2024, 2:30 PM"

3. The TC and FC envelopes should be enclosed in one mother envelope and must be labelled, sealed and signed as follows:

PREVENTIVE MAINTENANCE AND SERVICES FOR GENERATOR SETS FOR CY 2025

[NAME AND ADDRESS OF THE BIDDERS] BIDS AND AWARDS COMMITTEE SECRETARIAT UP OPEN UNIVERSITY UPOU HEADQUARTERS, LOS BAÑOS, LAGUNA REFERENCE NO. NP-TFB No. 24-12-002 "DO NOT OPEN BEFORE 10 December 2024, 2:30 PM"

